

## Exemption from provisions of Health and Safety at Work (Hazardous Substances) Regulations 2017

In accordance with section 220 of the Health and Safety at Work Act 2015 (the Act), I, Simon Humphries, Acting Deputy General Manager Investigations and Specialist Services of WorkSafe New Zealand, exempt **Tru-Tech Fibreglass Industries Limited** from compliance with regulation 11.37 of the Health and Safety at Work (Hazardous Substances) Regulations 2017 for the building type of its fibreglass workroom at 37 Wakefield Street, Onekawa, Napier.

I do so -

- being satisfied that:
  - a. the extent of the exemption is not broader than is reasonably necessary to address the matters that gave rise to it; and
  - b. the exemption is not inconsistent with the purpose of the Act; and
- subject to the conditions specified on the following page:

This exemption takes effect on **21 September 2018** and expires on **21 September 2023** unless it is replaced sooner or revoked.

Simon Humphries

Acting Deputy General Manager Investigations and Specialist Services

WorkSafe New Zealand

## **Exemption Conditions**

- 1. Installation of a wall with a fire resistance rating of not less than 120/120/120 minutes between the workshops and the office. All doors between the workshops and the office must have a fire resistance rating of not less than -/120/60 minutes.
- 2. An audible and visible alarm which operates whenever the air extraction system stops operating.
- 3. Installation of a cabinet which is compliant with AS 1940-2004 *The storage and handling of flammable and combustible liquids* for storing class 3.1B (acetone) when it is not in use.
- 4. Written operating procedures for the following circumstances:
  - a. The flammable substance vapour level reaches 150ppm.
  - b. The concentration of styrene reaches 10% of the LEL (1,100 ppm of styrene).
  - c. The air extraction system stops operating.
- 5. The fire extinguishers deployed throughout the fibreglassing area and site as shown in the site plan dated 10/06/07 and drawn by BC Trower must be maintained and have current certification.
- 6. The quantity of class 3.1C substances stored or used in the fibreglassing area must not exceed 750 L.
- 7. The quantity of class 3.1B (acetone) substances stored or used in the fibreglassing area must not exceed 60 L.
- 8. All workers working for Tru-Tech Fibreglass Industries Limited must receive two-yearly training in the use of fire extinguishers and training records must be kept as required under regulation 4.5(5).
- 9. A compliance certifier coming to the site for the purpose of issuing a location compliance certificate for the fibreglassing area must be provided with a copy of this exemption.
- 10. The exemption is revoked if:
  - a. There is a change to the layout of the site as shown in the site plan dated 10/06/07 and drawn by BC Trower; or
  - b. There is a change in ownership; or
  - c. Any of the conditions are not complied with.